



GUJARAT INDUSTRIES POWER COMPANY LIMITED

(SURAT LIGNITE POWER PLANT)

AT & PO. Nani Naroli, Taluka Mangrol, Dist. Surat - 394 112

Phone : EPABX (02629) 261063 to 261066 Fax : (02629) 261080 E-mail : genslpp@gipcl.com

APPENDIX – VIII

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Ref: SLPP/Civil/ 743

Date: 12/03/2025

It is certified that an inspection team headed by Kalpesh H. Mistry, AGM(Civil), from Civil Dept. of Gujarat Industries Power Company Limited, Nani Naroli, Ta.: Mangrol, Dist.: Surat inspected the Bharatiya Vidya Bhavan's GIPCL Academy at Nani Naroli, Ta.: Mangrol, Dist. Surat, Gujarat – 394 112 on 12/03/2025 and found that the Bharatiya Vidya Bhavan's GIPCL Academy has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

K.H. Mistry
12/03/25

(K. H. Mistry)
Add. General Manager (Civil)
GIPCL – SLPP. Nani Naroli.

To
The Principal
Bharatiya Vidya Bhavan's GIPCL Academy
At & Po.: Nani Naroli, Ta.: Mangrol
Dist.: Surat – 394 112, Gujarat

Registered Office & Vadodara Plant :
P.O. RANOLI, Dist. Vadodara 391 350 Gujarat - INDIA



Phone : EPABX (0265) 2230182 / 2230028 / 2232768
Fax : 2230029 E-mail : genbaroda@gipcl.com

Website : www.gipcl.com
CIN No.: L99999GJ1985PLC007868



DISTRICT LABORATORY
Gujarat Water Supply & Sewerage Board
SURAT



REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

Name & Address of Sender Sr. Manager Gujarat Industries Power Company Limited AT & Po. Nani Naroli, Ta-Mangrol Ta-Magrol Surat.	Sender's Ref. No:	Nil
	Date of Collection :	25/10/2024
	Date of Receipt at Lab.:	25/10/2024
	Sample collected by :	Sender
BW No.	SBW-314	
Date of Commencing Examination	25/10/2024	
Source of Water Sample	Treated Water	
Source Details	Of School Building	
Village	Nani Naroli	
Taluka	Mangrol	
District	Surat	
APHA-9222B, IS-15185:2016, ISO 9308-1:2014 Total Coliform Test.	<2	
APHA-9222D, IS-15185:2016, ISO 9308-1:2014 Thermotolerant Fecal coliform (<i>E. Coli</i>)	<2	
Free Chlorine (PPM)	0.30	
OPINION FOR POTABILITY AS PER THE BIS:10500:2012	FIT	

Note: Table-6 Bacteriological Quality of Drinking Water (BIS:10500:2012) Second Revision (Clause 4.1.1) :

- (i) All Water Intended for Drinking:
(a) E.coli or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.
(ii) Treated Water Entering the Distribution system:
(a) E.coli or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.
(b) Total coliform bacteria shall not be detectable in any 100ml sample.
(iii) Treated water in the distribution system:
(a) E.coli or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.
(b) Total coliform bacteria shall not be detectable in any 100ml sample.

- 1) Test Report is issued for assessing Bacteriological Fitness as per the BIS 10500:2012 for the given Drinking Water Sample only.
2) After Collection of Bact. Sample, it must be preserved at 4°C and submitted to laboratory within 24 hrs.

Chemical Sample Lab Reference No :-

SRT/Dist. Lab / SBW / 359 / of 2024

Date: 28 / 10 / 2024



LABORATORY INCHARGE