



# GUJARAT INDUSTRIES POWER COMPANY LIMITED

(SURAT LIGNITE POWER PLANT)

AT & PO. Nani Naroli, Taluka Mangrol, Dist. Surat - 394 112

Phone : EPABX (02629) 261063 to 261066 Fax : (02629) 261080 E-mail : genslpp@gipcl.com


## APPENDIX – VIII

### SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Ref: SLPP/Civil/646


Date: 11/03/2026

It is certified that an inspection team headed by Rajiv B. Soni, DGM(Civil), from Civil Dept. of Gujarat Industries Power Company Limited, Nani Naroli, Ta.: Mangrol, Dist.: Surat inspected the Bharatiya Vidya Bhavan's GIPCL Academy at Nani Naroli, Ta.: Mangrol, Dist. Surat, Gujarat – 394 112 on 11/03/2026 and found that the Bhartiya Vidya Bhavan's GIPCL Academy has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

  
(R. B. Soni)  
Dy. General Manager (Civil)  
GIPCL – SLPP. Nani Naroli.

  
Principal  
Bharatiya Vidya Bhavan's  
GIPCL Academy  
Nani Naroli, Ta : Mangrol,  
Dist.: Surat-394 112



  
Secretary  
BVB's GIPCL Academy

To  
The Principal  
Bhartiya Vidya Bhavan's GIPCL Academy  
At & Po.: Nani Naroli, Ta.: Mangrol  
Dist.: Surat – 394 112, Gujarat

Registered Office & Vadodara Plant :  
P.O. RANOLI, Dist. Vadodara 391 350 Gujarat - INDIA



Phone : EPABX (0265) 2230182 / 2230028 / 2232768

Fax : 2230029 E-mail : genbaroda@gipcl.com

Website : www.gipcl.com  
CIN No.: L99999GJ1985PLC007868



**DISTRICT LABORATORY**  
**Gujarat Water Supply & Sewerage Board**  
**SURAT**



**REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE**

Name & Address of Sender Sr. Manager ( C & L ) Gujarat Industries Power Company Limited AT & Po. Nani Naroli, Ta-Mangrol, Surat.	Sender's Ref. No:	Nil
	Date of Collection :	12/08/25
	Date of Receipt at Lab.:	12/08/25
	Sample collected by :	Sender
BW No.	SBW-310	
Date of Commencing Examination	12/08/25	
Source of Water Sample	Treated Water	
Source Details	School Building	
Village	Nani Naroli	
Taluka	Mangrol	
District	Surat	
APHA-9222B, IS-15185:2016, ISO 9308-1:2014 Total Coliform Test.	<2	
APHA-9222D, IS-15185:2016, ISO 9308-1:2014 Therotolerant Faecal coliform (E.Coli)	<2	
Free Chlorine ( PPM )	1.50	
OPINION FOR POTABILITY AS PER THE BIS 10500 2012	FIT	

Note Table-6 Bacteriological Quality of Drinking Water (BIS:10500:2012) Second Revision(Clause 4.1.1):  
 (i) All Water Intended for Drinking:  
 (a) E coli or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.  
 (ii) Treated Water Entering the Distribution system:  
 (a) E coli or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.  
 (b) Total coliform bacteria shall not be detectable in any 100ml sample.  
 (iii) Treated water in the distribution system:  
 (a) E coli or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.  
 (b) Total coliform bacteria shall not be detectable in any 100ml sample

1) Test Report is issued for assessing Bacteriological Fitness as per the BIS 10500:2012 for the given Drinking Water Sample only.  
 2) After Collection of Bact. Sample, it must be preserved at 4°C and submitted to laboratory within 24 hrs.

Chemical Sample Lab Reference No :-

SRT/Dist Lab / SBW / 301 / of 2025

Date: 13 / 08 / 2025

Principal

Bharatiya Vidya Bhavan's  
GIPCL Academy  
Nani Naroli, Ta: Mangrol,  
Dist: Surat-394 112



Secretary

BVB's GIPCL Academy

LABORATORY  
INCHARGE